

Yonkers Odor Control Study

Yonkers Joint Water Resource Recovery Facility

Chris Korzenko, P.E.
William Nylic, P.E.
Bruce Singleton, P.E.

March 28, 2018



**CDM
Smith**

Odor Control Study - Presentation Outline

- Introduction
- Purpose of Odor Control Study
- Background on Odor
- Sampling Overview
- Preliminary Findings

Introductions

CDM Smith Presenters

- Christopher Korzenko, P.E. – Project Director
- William Nylic, P.E. – Project Manager
- Bruce Singleton, P.E. – Odor Control Specialist

Firm Introduction

Company Background – CDM Smith

- Established in 1947
- More than 5,000 employees worldwide
- Services include consulting, engineering, construction, and operations
- Solutions in water, environment, transportation, energy, and facilities
- Experienced in the design and evaluation of odor control systems
 - Odor Source Surveys/Emissions Modeling/Dispersion Modeling
 - Technology Assessments
 - Process Cover Design/Odor Control Design
 - Construction Services

Purpose of Odor Control Study

Goal

- Identify sources of odors and develop recommendations to reduce offsite impacts

Areas of Focus

- Odors associated with taking tanks out of service
- Performance of Existing Odor Control Equipment
- Aeration Tank Odor Control
- Flare Operation

Odorants Background


- Odor is the sensing of the odorants
- Identifying the specific odorant leads to the solution
 - Odorous chemical compounds: Odorants
- Resident Odor Observations (in no particular order)
 - Chemicals
 - Dryer Sheets
 - Burning
 - Sewage
 - Rotten Food
 - Baby Diapers

Common Odorants in Wastewater

Odorant	Examples	Dominate
Hydrogen Sulfide		<ul style="list-style-type: none"> • Sewer Systems • Wastewater Treatment Systems
Organic Sulfur Compounds	<ul style="list-style-type: none"> • Dimethyl Sulfide • Methyl Mercaptan • Carbon Disulfide 	<ul style="list-style-type: none"> • Sludge holding, thickening, dewatering and stabilization processes
Nitrogen Compounds	<ul style="list-style-type: none"> • Ammonia • Amines • Skatole • Indole 	<ul style="list-style-type: none"> • Wastewater anoxic basins • Sludge digestion (anaerobic, ATAD) • Sludge lime stabilization
Volatile Fatty Acids	<ul style="list-style-type: none"> • Acetic Acid • Butyric Acid • Valeric Acid 	<ul style="list-style-type: none"> • Gravity thickeners • ATAD
Aldehydes and Ketones	<ul style="list-style-type: none"> • Acetaldehyde • Methyl Ethyl Ketone • Acetone 	<ul style="list-style-type: none"> • Sludge holding, thickening, dewatering and stabilization processes

Data Collection

- Preliminary Data Collection
 - Collaborative Review of Existing Data with Plant Staff
 - Interviews
 - Plant preferences
 - Plant operations data
 - Odor control process data
 - Odor complaint logs
 - Current data
- Supplemental Data Collection
 - Existing Equipment Assessment
 - Collection and conveyance
 - Treatment Processes
 - Liquid Phase Data
 - Vapor Phase Data



Sampling Plan Overview

- Comprehensive review of existing emission sources
 - Chemical scrubbers
 - Performance
 - Open Tanks and channels
- Investigation of fugitive emissions sources
 - Leaks in covers
 - Incomplete/unbalanced ventilation
- Interior ventilation
 - Unbalanced ventilation
 - Odorous rooms exposed to the outside

Sampling Program – Field Equipment Used

Used a variety of sampling methods to capture maximum amount of odorants

- Colormetric Tubes for specific analytes, NH_3
- H_2S Sensors and Data Loggers
- Equipment for liquid measurements




Measuring Odor

- Samples collected and sent off-site to an “odor laboratory”.
- Use “forced-choice” olfactometer
- Odor concentration
 - Expressed as dilutions-to-threshold, (D/T) or odor units (OUs).
 - Detection level determined by human panelists
- Done in accordance with industry-accepted international standard
 - EN 13725:2006




Application of Data: Modeling Example

- Dispersion Analysis
 - Plant wide source sampling
 - H₂S
 - VOCs
 - Odors
 - Local Meteorological data
 - Local Topography
 - Local Complaints
- Provides an assessment of the current (baseline) odor effects
- Confirms the effects of emissions and treatment of various sources.



Wind Data

- Termed a “Wind Rose”
- Indicates direction wind is blowing from
- Created with five years of plant data
- Prevailing winds are:
 - Northwest
 - Southwest




Odor Magnitude and Frequency Plots



- Next Pages show two plots
- Left Hand Side – Magnitude Isopleth
 - Indicates maximum odor strength
 - Averaged at five minute intervals
- Right Hand Side – Frequency
 - Indicates maximum number of exceedances greater than 7 OUs possibly detected during over a 5 year period
 - 7 OUs (odor units) is an industry standard for a nuisance odor

Review of Strongest Odor Sources

- Common exhaust for Mist Scrubbers 2, 3, and 4 and the Severn Trent Three Stage Scrubbers 1 and 2.
- Siemens Dual Stage LoPro Scrubbers 1, 2, and 3
- Mist Scrubbers A, B, and C
- Aeration tanks



Baseline Odor Strength and Frequency



Scrubbers A, B, and C


- Scrubbers A, B, and C treat air from the Primary Settling Tanks.
- Two scrubbers operate at a time with one as stand-by.
- H₂S levels 10 -12 ppm maximum
- Exhaust odor was high indicating problems with the scrubber operation due to internal mechanism or chemistry.
- Creates odor levels up to 20 OUs east of the plant
- Frequency of impacts > 7 OUs, up to 500 times/ 5 years
- Low OUs, high frequency





Scrubber 2, 3, and 4 and Severn Trent Scrubber 2: Common Exhaust

2: Common Exhaust

- Scrubbers 2, 3, and 4 mist scrubbers treat emission from the primary thickening building, overflow tanks, and sludge storage tanks. Only Scrubbers 3 and 4 were operating (scrubber 2 in stand-by mode).
- Severn Trent Scrubber 2, three stage treats air from the dewatering building
- Low loading rates for H₂S and organics
- Odor removal is mixed but not optimized for scrubbers 2, 3, and 4
- Odor removal at <90% for Severn Trent Scrubber 2
- Odor levels of 41 OUs east of the plant
- Frequency of impacts > 7 OUs, up to 100 times/5 years.
- Odor removal performance requires improvement
- Moderate OUs, moderate frequency



Strength and Frequency Plots for Common Exhaust




Siemens LoPro Scrubbers

- Scrubbers 1, 2, and 3 treat air from the headworks
- Only Scrubber 1 was operating as the ventilation to the other scrubbers was not yet installed
- Lightly loaded
- Odor concentrations inlet and outlet were low
- Scrubber exhaust goes to a dispersion fan
- Low odor exhaust no offsite impacts
- Low OUs, low/no frequency




Dispersion Fan Odor Strength and Frequency





Aeration Tanks

- Large open and aerated ground level emission source
- Low H_2S and organic sulfur compound levels
- No treatment
- Odor levels to 50 OUs east of the plant
- Frequency of impacts > 7 OUs, up to 500 times/5 years
- Moderate OUs, high frequency




Aeration Tanks Odor Strength and Frequency



Aeration Tank Plot with Complaint Occurrences

- Represents complaints received in 2017
- Frequency plot of aeration tanks
- Location of complaints correlates with odor frequency



Additional Ongoing Odor Control Measures

- Potassium Permanganate Building (KMnO₄) is being constructed
- Chemical addition oxidizes hydrogen sulfide and organic odors
- Provides an oxidizing environment to convert hydrogen sulfide back to sulfate
- Helps to eliminate “rotten egg” odor



Operational Conclusions

- Scrubbers 2, 3, and 4
 - Well operated
 - Air flow should be decreased
 - Internal liquid nozzle should be inspected
- Severn Trent Scrubbers
 - Recirculation system should be evaluated: nozzles etc
 - Inspect packing
 - Media cleaning
- Siemens LoPro w/ Strobic
 - Operating as designed
- Scrubbers A, B, and C
 - Internal liquid nozzle should be inspected
- Aeration tanks
 - Greatest offsite odor impact

Next Steps

- Structural Inspections of Scrubbers
 - Provide recommendations
- Grit and Primary Tanks
 - Review out of service procedures
 - Provide strategy for containing odors
- Aeration Tanks and Influent/Effluent Channels
 - Provide conceptual layout
 - Complete cost estimate
- Final Report
- Schedule
 - Plan on presenting completed results by next meeting

Questions?